






Profile View RHS
Door Open


Profile View LHS
Door Closed



External View




Internal View
Escutcheon On



Internal View

Component Details		Dwg Reference
Enclosure	AS/NZ3012 Galvanised Powdercoated Steel X-15,Orange, IP44, Pad Lockable	(1)
Main Switch	100A 3P Isolator, Wired from Single Pole on Load Side	(2)
RCBOs	20A 1P, 6kA, Double Pole	(3)
GPOs	Double Gang, 10A Outlet	(4)
GPOs	Single Gang, 15A Outlet	(5)
Blank Plates	Blank Plates for Future GPO Positions	(6)
Active Links	Red 4 Hole 165A Sealable Active Link for 25mm Mains	(7)
Neutral Link	Black 4 Hole 165A Sealable Neutral Link for 25mm Mains	(8)
Earth Bar	100A 12 way	(9)
Neutral Bar	100A 12 way	(10)
RCD Cover	Galvanised Powdercoated Steel, X-15 Orange, Pad / Key Lockable	(11)
Door Stay	Galvanised Powdercoated Steel Door Retainer	(12)
Compliance Stickers	AS/NZ 3012 Sticker Kit	(13)



SLD

AMENDMENTS		
REV:	DATE:	DESCRIPTION:
A	19/10/2020	Temporary Power Boards
B	4/06/2025	Temporary Power Boards
THESE DRAWINGS REMAIN THE PROPERTY OF DSD AND CANNOT BE REPRODUCED WITHOUT PRIOR WRITTEN CONSENT		



Unit 3 6-10 Octal Street
Yatala, QLD, 4207
TEL : 07 5597 1102



Project:
Temporary Power Boards TPB-3PT4

Title:	TPB-3PT4
Scale:	NTS
Date:	4/06/2025
Approved:	

Document ID:	Rev:
TPB-3PT4	B